

Saturn Studio II - STL Advanced Report Generator Version 1.01

Index

1	Saturn Studio II – STL Analysis Suite	3
2	Standard Reports of STL Packages	4
2.1	<i>Document Structure</i>	4
2.2	<i>Example Reports</i>	5
3	Advanced Report Generator	8
3.1	<i>Working with the Advanced Report Generator</i>	8
3.2	<i>Example: Advanced Report Generator</i>	13
4	Contact	15

1 Saturn Studio II – STL Analysis Suite

The Saturn Studio II – STL Analysis Suite is a fully automatic analysis package for typical high voltage tests.

The Short-Circuit Testing Liaison (STL) provides a forum for voluntary international collaboration between testing organizations. The basic aim is the harmonized application of IEC and Regional Standards to the type testing of electrical power equipment.

The analysis is based on the recommendations of the short-circuit testing liaison STL www.stl-liaison.org.

2 Standard Reports of STL Packages

In addition to the powerful analysis and individual test reporting in Saturn Studio II – STL Analysis Suite AMOTRONICS offers the STL Report Generator module.

The Advanced Report Generator is a tool to summarize all results of different tests for one test object in a global test report.

This chapter describes some basic report features about the STL Analysis Suite, chapter 3 “Advanced Report Generator” presents the additional functions with the Report Generator.

2.1 Document Structure

All available STL-Packages automatically generate three different result-documents:

1. Text-File with all results (result.txt)

Very simple to use for own programming and documentation utilities.

2. Word document with summarized results (*.doc)

A one page word report with the summarized results of the test.

3. A fully detailed PDF document with all calculation results step by step

Multi-Page report with detailed calculations of (depending on STL-package):

- operation detection
- travel
- current signals
- voltage signals
- TRV analyze

For some of the calculations no load and prospective test analyses are necessary prior to the real tests. The software supports this kind of dependencies between the tests.

2.2 Example Reports

```
[RESULT]
tcl_L1_1=-
top_L1_1=46.5
tcl_L1_2=55.2
top_L1_2=45.1
Test_1=3
Test_2=3
trial=COMBI
topen_L1=73.028
tclose_L1=372.848
operation=OCO
travel=YES
tcl_L2_1=-
top_L2_1=46.6
tcl_L2_2=55.0
top_L2_2=45.2
topen_L2=73.148
tclose_L2=372.678
tcl_L3_1=-
top_L3_1=46.8
tcl_L3_2=54.9
top_L3_2=45.4
topen_L3=73.338
tclose_L3=372.548
CT=-671.563
CS=-661.250
CT_rel=66.872
CS_rel=68.246
U_MAX=-422.808
U_MIN=-1173.705
tcl=55.1
top=46.6
Uod_1=110
Uod_2=110
Ucd_1=-
Ucd_2=110
op_1=O
op_2=CO
```

Test Results

No-Load Operations

Test performed: No-load operations

Date of test: 13th September 2006

Condition of test object before test: Factory new.

Gas pressure (abs. rel. to 20 °C): -

Test No.	COMBI			3				
Operating sequence				O-0.3s-CO		O-0.3s-CO		O-0.3s-CO
C-Operation	Voltage of closing device	V		110				
	Closing time	L1	ms	55.2				
		L2	ms	55.0				
		L3	ms	54.9				
O-Operation	Voltage of opening device	V	110	110				
	Opening time	L1	ms	46.5	45.1			
		L2	ms	46.6	45.2			
		L3	ms	46.8	45.4			

Legend: -

Remarks:

Figure 1: Example for NO LOAD TEST ... No_Load_E.doc (formatted Word file)

Figure 2: Example for NO LOAD TEST ... Result.txt (simple text file)





Figure 3: Synthetic Test Report



3 Advanced Report Generator

The Advanced Report Generator is a tool to summarize all results for one test object in a global test report. The single test projects are automatically archived and sorted in a hierarchical file structure called "campaign". Each campaign represents a number of tests for the same DUT (Device Under Test).

After finishing all tests and calculation of all results the REPORT GENERATOR can be used to generate a complete report by automatically combining different predefined templates, tables and pictures.

3.1 Working with the Advanced Report Generator

The generator starts by selecting a target report out of a list of available predefined templates:




Figure 5: Document Selector

After selecting of the report type, the program automatically knows the structure of the document and guides the user through a number of selection menus to specify the content in detail. The program evaluates the relation between all tests and shows only reasonable options for selection.

Example of selecting the synthetic tests to be used in the report:





Figure 6: Test Selector for SYT

After selection of all synthetic tests for the report, the user has the possibility to adjust the column and table position of the results. The software does automatically increments the number of required multicolumn tables.



Column and table arrangement can be easily arranged by mouse functions

10

Figure 7: Test Selector for SYT

Depending on the arrangement of test 10+12 (in above example) for the first table and test 17-20 for the second table the software will automatically generate two tables in the report:

Laboratories Aachen

AMO
tronics

Report No.: 99999

Sheet 13

Test Results

Basic Short-Circuit Test Duty T60

Test performed:

Basic short-circuit making and breaking tests (T60)

Date of test:

17 September 2009

Condition of test object before test:

Factory new.

Test arrangement:

Direct test circuit, vacuum circuit-breaker in metal-enclosed, air-insulated switchgear

Connections to test object:

Infeed via copper test to the busbar of the metal-enclosed, air-insulated switchgear. Short-circuited at the cable terminal of the switchgear via copper test, short-circuit point and switchgear earthed via cable.

Gas pressure (abs. rel. to 20 °C):

Test No.	COMBI	10	12				
Operating sequence and time intervals		O	CO				
Applied voltage	kV		6.00				
Making current (peak)	L1 kA		25.0				
	L2 kA		18.8				
	L3 kA		22.8				
Breaking current (r.m.s.)	L1 kA	16.4	9.67				
	L2 kA	17.1	10.2				
	L3 kA	17.0	10.1				
Average value	kA	16.9	9.99				
Recovery voltage (r.m.s.)	L1 kV	0.000	3.16				
	L2 kV	0.000	3.33				
	L3 kV	0.000	3.34				
Average value between phases	kV	10.0	5.67				
Transient recovery voltage	Voltage u_r						
	Time t_r						
TRV peak value u_r	kV	18.5	10.5				
	Time t_r						
	Time delay t_r						
	Rate of rise u_r/t_r	kV/μs	0.314	0.186			
C-Operation	Voltage of closing device	V	110				
	Closing time	ms	59.2				
	Pre-arcing time	ms	0.480				
	Make time	ms	58.7				
O-Operation	Voltage of opening device	V	110	110			
	Opening time	ms	46.5	58.8			
	Arising time L1	ms	7.83	6.85			
	L2	ms	7.79	6.85			
	L3	ms	2.97	1.99			
	Break time	ms	54.3	65.6			
Emission of flame/gas/oil, occurrence of NSDD	no	no	no	-	-	-	-
Number of valid test	1	2	3	-	-	-	-
Test result	P	P	P	-	-	-	-

Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard

Remarks: 99999 / 01:

Current calibration

99999 / 02:

No-load operation

99999 / 03 to 05:

Tests with reduced values

Condition of test object after test: Test object not inspected, continued with test duty CC2

Laboratories Aachen

AMO
tronics

Report No.: 99999

Sheet 14

Test Results

Basic Short-Circuit Test Duty T60

Test performed:

Basic short-circuit making and breaking tests (T60)

Date of test:

17 September 2009

Condition of test object before test:

Factory new.

Test arrangement:

Direct test circuit, vacuum circuit-breaker in metal-enclosed, air-insulated switchgear

Connections to test object:

Infeed via copper test to the busbar of the metal-enclosed, air-insulated switchgear. Short-circuited at the cable terminal of the switchgear via copper test, short-circuit point and switchgear earthed via cable.

Gas pressure (abs. rel. to 20 °C):

Test No.	COMBI	17	18	19	20		
Operating sequence and time intervals		O	O	O	C		
Applied voltage	kV						
Making current (peak)	L1 kA				51.7		
	L2 kA				40.6		
	L3 kA				44.1		
Breaking current (r.m.s.)	L1 kA	18.8	19.7	18.9	20.8		
	L2 kA	18.8	20.5	20.7	21.4		
	L3 kA	19.6	19.6	20.5	21.6		
Average value	kA	19.1	19.9	20.1	21.2		
Recovery voltage (r.m.s.)	L1 kV		6.78		6.71		
	L2 kV		6.95		6.93		
	L3 kV		6.88		6.78		
Average value between phases	kV		11.3		11.3		
Transient recovery voltage	Voltage u_r						
	Time t_r						
TRV peak value u_r	kV	21.2	22.4	22.6	0.000		
	Time t_r						
	Time delay t_r						
	Rate of rise u_r/t_r	kV/μs	0.362	0.388	0.386		
C-Operation	Voltage of closing device	V				110	
	Closing time	ms				0.000	
	Pre-arcing time	ms				34.7	
	Make time	ms				139.8	
O-Operation	Voltage of opening device	V				110	
	Opening time	ms				46.2	
	Arising time L1	ms				2.15	
	L2	ms				6.17	
	L3	ms				6.20	
	Break time	ms				52.4	
Emission of flame/gas/oil, occurrence of NSDD	no	no	no	-	-	-	-
Number of valid test	1	2	3	-	-	-	-
Test result	P	P	P	-	-	-	-

Legend: P: Passed in terms of the applied standard N: Not passed in terms of the applied standard

Remarks: 99999 / 01:

Current calibration

99999 / 02:

No-load operation

99999 / 03 to 05:

Tests with reduced values

Condition of test object after test: Test object not inspected, continued with test duty CC2

Figure 8: (preview of the later result)

The report tool continues with different selection menus for all other tests to be integrated in the report:





Figure 9: Several Test Selection Windows

After selection of all tests it is possible to define drawings and screenshots to be added to the report:




12

Figure 10: Additional Graphics Selection Windows

The report generator displays a list of all previously captured screenshots and drawings of the campaign and the related projects. It is also possible to use images or photos from outside of the selected project and campaign hierarchy.

The integrated preview window supports the selection of correct files.

The resulting report will be generated...



...and automatically opened on the PC.

3.2 Example: Advanced Report Generator




Figure 11: Example of a simple multipage report




Figure 12: Extract of a simple multipage report

4 Contact

Products of AMOTRONICS' Saturn transient recorder family are distributed all over the world. Please contact the following address for your inquiries:

15



Roermonder Strasse 594
52072 Aachen
GERMANY

www.amotronics.de

info@amotronics.de

Tel: +49 241 169780 28

Fax: +49 241 169780 55



Axilane Instruments SARL

81 rue des Joncs Marins, 91620 La Ville du Bois
www.axilane.com - info@axilane.com

Tél : +33.(0).950.60.40.20 - Fax : 09.50.60.40.20
N° 478891641 RCS EVRY